Stanwade Metal Products, Inc.
6868 State Route 305 PO Box 10
Hartford, Ohio 44424
Phone: 800-826-5243 Fax. 1-330-772-3307
www.tankstore.com







Capacity 6,000 Gallons

Design Doublewall Vertical

Code UL 142 Flameshield

Test Pres. 2-1/2 PSI

Heads Primary 1/4"

Secondary 1/4"

Shell Primary 1/4"

Secondary 10 Gauge

Paint Ext. White Urethane

Paint Int. _____

Weight Empty 9,300 lbs.

Drawing # _____

Scale _____

Spec. Note:

Tank For Stationary Use Only

FLAMESHIELD
Tested to NFPA 30A Fire-Resistant Tank Requirements

Quote# _____

Quoted Lead Times Begin Upon Receopt of Signed Approved Drawing, Which Must be Returned Before Production Can Begin

Drawing Approved By:

_____