



STANWADE METAL PRODUCTS, INC.

6868 State Route 305, P.O. Box 10
 Hartford, Ohio 44424
 Phone: 800-826-5243 Fax: 1-330-772-3307
 www.tankstore.com


FLAMESHIELD

Tested to NFPA 30A Fire-Resistant Tank Requirements

Capacity: <u>12,000 Gallons</u>	Primary Heads: <u>1/4"</u>	Paint Ext.: <u>White Urethane</u>
Design: <u>Double Wall Abvground</u>	Primary Shell: <u>1/4"</u>	Paint Int.: <u>N/A</u>
Code: <u>UL 142, Flameshield</u>	Secondary Heads: <u>1/4"</u>	Weight: <u>19,200 Lbs.</u>
Test Pres.: <u>5 P.S.I.</u>	Secondary Shell: <u>10 Ga.</u>	

Notes:

1. Tank For Stationary Use Only.
2. Must Be Open Atmospheric Vented.
3. Dimensions Shown Are Interior.
4. All Openings Are Female Threaded Unless Noted Otherwise.



Customer: _____

Drawing Date: _____

Drawing #: _____

Drawing Approved By: _____

Quote #: _____

Quoted Lead Times Begin Upon Receipt of Signed Approved Drawing, Which Must be Returned Before Production Can Begin.